

JOHN H. ALLGAIR, PE, PP, LS (1983-2001)
DAVID J. SAMUEL, PE, PP, CME
JOHN J. STEFANI, PE, LS, PP, CME
JAY B. CORNELL, PE, PP, CME
MICHAEL J. McCLELLAND, PE, PP, CME
GREGORY R. VALES, PE, PP, CME



TIM W. GILLEN, PE, PP, CME (1991-2019)
BRUCE M. KOCH, PE, PP, CME
LOUIS J. PLOSKONKA, PE, CME
TREVOR J. TAYLOR, PE, PP, CME
BEHRAM TURAN, PE, LSRP
LAURA J. NEUMANN, PE, PP
DOUGLAS ROHMEYER, PE, CFM, CME
ROBERT J. RUSSO, PE, PP, CME
JOHN J. HESS, PE, PP, CME

August 23, 2021

Hazlet Township Land Use Board
1766 Union Avenue
Hazlet, NJ 07730

Attn: Laura McPeek
Land Use Board Secretary

**Re: Georgetown Realty Associates (Owner)
Krishna Restaurants, LLC (Applicant)
Minor Site Plan Application (App 21-11L)
Completeness & Technical Engineering Review #2
Location: 734 NJSH Route 36
Block 120, Lot 1.01 (IA Zone)
Hazlet Township, Monmouth County, NJ
Our File: HHZL0120.05**

Dear Land Use Board Members:

Our office has received the following supplemental submission items in response to our original review letter, dated June 2, 2021:

- Plan entitled, "Proposed Burger King With Double Drive-Thru For Georgetown Realty Associates; Plate 1.05, Block 120, Lot 1.01 - 734 N.J.S.H. Route 36, Hazlet Township, Monmouth County, New Jersey", prepared by Michael D. Galante, P.E. of MG Engineering Associates, LLC, consisting of five (5) sheets, dated March 2021, last revised June 16, 2021;
- Revised "Land Use Board Application" reflecting change of Applicant's Name, Property Owner's Signature and include Disclosure of Ownership Statement.

Previously, our office reviewed the following:

- Plan entitled, "Proposed Burger King With Double Drive-Thru For Georgetown Realty Associates; Plate 1.05, Block 120, Lot 1.01 - 734 N.J.S.H. Route 36, Hazlet Township, Monmouth County, New Jersey", prepared by Michael D. Galante, P.E. of MG Engineering Associates, LLC, consisting of five (5) sheets, dated March 2021, unrevised;
- Plan entitled, "Boundary & Topography Plan, #734 Route No. 36, Lot 1.01, Block 120, Plate 1.05, Hazlet Township, County of Monmouth, New Jersey", prepared by Philip J. Schaeffer, P.L.S. of JTS Engineers & Land Surveyors, Inc., consisting of one (1) sheet, dated August 3, 2020, unrevised;
- Copy of application to Monmouth County Planning Board
- Copy of Completed Environmental Assessment Checklist;

S:\Hazlet\Project Files\L0120.05 - Georgetown Realty Associates\Review Phase\CME & Board Prof Review Reports & Correspondence\21-08-23 LUB Completeness Eng Rev#2.docx




Hazlet Township Land Use Board
Re: Georgetown Realty Associates – Minor Site Plan Application
Completeness & Technical Engineering Review #2

August 23, 2021
HHZL0120.05
Page 2

- Copy of application to Bureau of Fire Prevention; and
- Completed Application Forms, including Land Use Board Application, Development Application & Development Plan Checklist and W-9 Request for Taxpayer Certification.

Based on our review, we offer the following:

- 1) The Applicant, Georgetown Realty Associates, is seeking Minor Site Plan approval to expand the existing single lane drive-thru into a double lane drive-thru within the existing Burger King parking lot. Other improvements include reconstruction of two (2) ADA parking spaces with associated curb ramps, storm inlet relocation and construction of new curb and new dumpster enclosure. The proposed improvements will reduce parking supply by 8 spaces to accommodate the double lane drive-thru, leaving a proposed total of 44 parking spaces whereas 40 spaces are required.





Hazlet Township Land Use Board
Re: Georgetown Realty Associates – Minor Site Plan Application
Completeness & Technical Engineering Review #2

August 23, 2021
HHZL0120.05
Page 3

- 2) The subject property is located at #734 Route 36, along NJSH Route 36 southbound just after the intersection of NJSH Route 36 with Union Avenue. Access to the property is provided via a right-in driveway and another right-out driveway along Route 36 southbound and an alternative two-way access driveway to Union Avenue, both to remain undisturbed. The site is located in the I-A (Industrial Assembly) Zoning District. Presently, the site contains the existing Burger King fast food restaurant. The property is located in the Flood Hazard Zone “AE-11” as noted on the FEMA Flood Maps, wherein freshwater wetlands associated with East Creek occupy the undeveloped portion of the site. The property is located in the CAFRA Zone.
- 3) The Applicant has not requested any variance relief and none appears to be required.
- 4) The Applicant has requested the following submission waivers:
 - a) **Preliminary and Major Subdivision Approval Checklist Item U.(5)6.:** Environmental Impact Report.

Given the scope of the project and the fact that all proposed development is within previously disturbed areas, our office has no objection to this waiver.

We recommend this application be deemed **COMPLETE** and have no objection to the application being scheduled for a public hearing.

Enclosed please find our Technical Engineering Review No. 2. The Applicant remains responsible to address the comments contained therein.

Should you have any questions or require additional information, please do not hesitate to contact this office.

Very truly yours,

CME Associates

Kurt Otto, PE, PP, CME, CFM
Land Use Board Engineer

KO:LZ:mrm
Enclosure

cc: Greg Vella, Esq., Board Attorney
Sharon Keegan, Zoning Board Officer
Krishna Restaurants, LLC, Applicant
Michael Galante, P.E., Applicant's Engineer
David Shafkowitz, Applicant's Attorney

JOHN H. ALLGAIR, PE, PP, LS (1983-2001)
DAVID J. SAMUEL, PE, PP, CME
JOHN J. STEFANI, PE, LS, PP, CME
JAY B. CORNELL, PE, PP, CME
MICHAEL J. McCLELLAND, PE, PP, CME
GREGORY R. VALES, PE, PP, CME



TIM W. GILLEN, PE, PP, CME (1991-2019)
BRUCE M. KOCH, PE, PP, CME
LOUIS J. PLOSKONKA, PE, CME
TREVOR J. TAYLOR, PE, PP, CME
BEHRAM TURAN, PE, LSRP
LAURA J. NEUMANN, PE, PP
DOUGLAS ROHMEYER, PE, CFM, CME
ROBERT J. RUSSO, PE, PP, CME
JOHN J. HESS, PE, PP, CME

HAZLET TOWNSHIP LAND USE BOARD

Existing Burger King with Proposed Double Drive-Thru Minor Site Plan

Block: 120, Lot: 1.01

Applicant: Krishna Restaurants, LLC

HHZL0120.05

TECHNICAL ENGINEERING REVIEW NO. 2

1. The parking lot appears to be in need of pavement repair. We note that construction and repair are proposed solely for the ADA parking spaces and the drive-thru areas. We recommend that the areas of the parking lot showing signs of rutting and alligator cracking be repaired in accordance with Section 181-512B.4, and all parking lots and loading areas shall be constructed or repaired to specifications as approved by the Township Engineer.
2. Provide a circulation plan to demonstrate that access to the proposed dumpster is feasible.
3. Indicate how ingress and egress to the four (4) spaces from the second drive-thru lane will be achieved if a drive thru queue is formed.
4. Provide more signage or pavement markings, including traffic arrows, to direct traffic circulation to the drive-thru areas, as well as the queue area.
5. The need to restripe some areas of the parking lot should be considered, including parking lane striping and pavement arrows, etc.
6. Indicate the grate elevation of the proposed type 'A' inlet. A detail of same should also be provided.
7. Provide a bicycle safe grate casting detail for the proposed type 'A' inlet.
8. Revise the reinforced concrete detail to indicate the concrete thickness.

We reserve the right for future comments pending receipt of revised plans.

The Applicant should indicate the status of all required outside agency approvals as required, including but not limited to, the following:

- i. NJDOT
- ii. NJDEP (CAFRA)
- iii. Monmouth County Planning Board
- iv. Hazlet Township Fire Prevention Bureau
- v. Hazlet Township Police Department
- vi. Freehold Soil Conservation District